

We offer

Industrial temperature sensors
Compensating cables
Glass thermometers
Temperature transmitters
Humidity transmitters
Pressure transmitters
Manometers
Valves
Indicators
Thermostats
Controllers
Relays
Recorders
Calibrators
Calibration furnaces
Heating elements

EU - DECLARATION OF CONFORMITY

Manufacturer: LIMATHERM SENSOR Sp. z o.o.
34-600 Limanowa, Skrudlak 1 Street

declares under the sole responsibility, that:

Head-type temperature sensors type:

..T..GB-..Exi-..., ..T..GN-..Exi-..., ..T..T-..Exi-..., ..T..P-..Exi-..., ..T..I-..Exi-...,
..T..SW-..Exi-..., ..T..SWG-..Exi-..., ..T..SWT-..Exi-..., ..T..GWN-..Exi-...,
meet the essential requirements of safety and health

Directive 2014/34/UE of 26 February 2014 and harmonized standards:

EN IEC 60079-0:2018, EN 60079-11:2012, EN 50303:2000,







what was confirmed by **EU-Type Examination Certificate KDB 07ATEX0055X 1st edition** dated 22.08.2022 and the **Notification of a Quality Assurance no. GIG 21 ATEXQ070** dated 15.02.2021

issued by:

**Central Mining Institute
Notified Body No. 1453**

40-166 Katowice, Plac Gwarków 1

Above listed sensors obtain marking:

CE 1453  I M1 Ex ia I Ma or
 II 2G Ex ia IIC T6-T1 Gb or
 II 2G Ex ia IIC T4-T1 Gb or
 II 2G Ex ia IIC T3-T1 Gb or
 II 1/2G Ex ia IIC T4-T1 Ga/Gb or
 II 1D Ex ia IIC T85 °C Da

Conditions of use:

Sensors installation and connection acc. to manual and safety
no. DTR-EExi-GŁ01.



District Court for
Cracow-City Center
XII Wydz. Gospodarczy
KRS 0000201394

Management
Zbigniew Juszkiewicz
Capital
700 000 zł
VAT No: 737-19-66-189

Chairman of the Board
Chief Executive Officer


mgr inż. Zbigniew Juszkiewicz

Limanowa, 10th Juli 2023
/issued date/